



2022 & 2025 Title 24 Kitchen Range Hood Verification Protocol

To ensure compliance with the California Title 24 Energy Efficiency Standards (2022), kitchen range hoods must meet specific airflow and sound performance requirements. This is a hers verified measure and is required per your the title 24 calculations. In order to comply the installed hood must be on the CEC/HVI approved list and meet the below ratings. All hers verifiable measures must comply and say complete in the hers provider's registry for any jurisdiction to sign on the final inspection.

Protocol for Compliance:

1. Minimum Airflow:

2. For electric ranges: 100 CFM (cubic feet per minute)

3. For gas ranges: 100 CFM per 10,000 BTU/hr of burner capacity, minimum 100 CFM

4. Sound Rating:

5. Maximum 3.0 sones at the required airflow rate

6. Certified Product Listing:

7. The installed kitchen range hood must be listed on the Home Ventilating Institute (HVI) Certified Products Directory.

8. **HVI Certified Products List:** [Click here to access the HVI Certified Products Directory](#)

*****And refer to pdf list in email*****

Kitchen Hood Description

Make
Model
Rated Airflow (CFM)
Sound Level (Sones)
Listed on HVI Directory (Yes/No)